

DECLARATION of PERFORMANCE

Number: BR-237

1. Unique identification code of the product:

H07Z1-U Classification Report Number: Nr 5943-3/2017

Number of conductors: 1

Conductor section (mm²): 1.5 -2.5

2. Intended use of the product:

It is used in hotels, schools, high buildings, hospitals, data processing centers and crowded business centers and fire-sensitive areas.

Manufacturer:

BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

4. System of assessment and verification of constancy of performance of the product

System 3

The range of cables described in 1&2 belongs to Euroclass Dca-s1,d1,a1 Euroclass Dca-s1,d1,a1 equals to System 3

5. Notified Body: Nr 2659

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Dca-s1,d1,a1	
Dangerous substances	None	EN 50575:2014/A1:2016

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

Product Development Manager:

İbrahim KILIÇ 19.02.2018

Borsan Kablo Elektrik Aydınlatma Aş.

OSB Organize Sanayi Bulvarı No: 40-1

Tekkeköy / Samsun

T: +90 (362) 266 5925

F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Vali M. Erdoğan Cebeci Bulvarı No: 54 Tekkeköy / Samsun

T: +90 (362) 266 9914 F: +90 (362) 266 9989

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr ORSAN KABLO ELEKTRIK



DECLARATION of PERFORMANCE

Number: BR-219

1. Unique identification code of the product:

H07Z1-U **Classification Report Number: NB 1783-CPR-1010**

Number of conductors: 1 Conductor section (mm²): 4-6

2. Intended use of the product:

It is used in hotels, schools, high buildings, hospitals, data processing centers and crowded business centers and fi re-sensitive areas.

3. Manufacturer:

> BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

4. System of assessment and verification of constancy of performance of the product

System 1

The range of cables described in 3&4 belongs to Euroclass Cca-s1,d1, a1 Euroclass Cca-s1,d1, a1 equals to System 1

NB 1783 5. Notified Body:

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Cca-s1 ,d1, a1	
Dangerous substances	None	EN 50575:2014/A1:2016

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

Product Development Manager:

İbrahim KILIÇ 10.12.2019

Borsan Kablo Elektrik Aydınlatma Aş.

OSB Organize Sanayi Bulvarı No: 40-1

Tekkeköy / Samsun

T: +90 (362) 266 5925 F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Vali M. Erdoğan Cebeci Bulvarı No: 54

Tekkeköy / Samsun

T: +90 (362) 266 9914 F: +90 (362) 266 9989

E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr