

DECLARATION of PERFORMANCE

Number: BR-206

1. Unique identification code of the product:

J-H(ST)H..Lg

Classification Report Number: NB 1783-CPR-1001

Number of conductors: 2 - 28

Conductor section (mm²): 0.6 - 0.8

Intended use of the product:

These cables are used for signaltransmission at fixed indoorinstallation with screen to protect theelectricalinterferences, in security andfire alarm system places where toxicgases should not exist.

3. Manufacturer:

> BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

System of assessment and verification of constancy of performance of the product

System 1

The range of cables described in 1&2 belongs to Euroclass Cca-s1a, d1, a1 Euroclass Cca-s1a, d1, a1 equals to System 1

NB 1783 5. Notified Body:

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Cca-s1a, d1, a1	
Dangerous substances	None	EN 50575:2014/A1:2016

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

Product Development Manager:

İbrahim KILIÇ 22.11.2019

ORSAN KABLO ELEKTRIK STORILING BE SAN WITE AL

Borsan Kablo Elektrik Aydınlatma Aş.

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Organize Sanayi Bulvarı No: 40-1

Tekkeköy / Samsun

T: +90 (362) 266 5925 F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr

OSB Vali M. Erdoğan Cebeci Bulvarı No: 54 Tekkeköy / Samsun

T: +90 (362) 266 9914 F: +90 (362) 266 9989 E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr



DECLARATION of PERFORMANCE

Number: BR-210

1. Unique identification code of the product:

JE-H(ST)H Bd Classification Report Number: 496997/11-19

Number of conductors: 2 - 4

Conductor section (mm²): 1.00 - 1.50

2. Intended use of the product:

These cables are used for signal transmission at fixed indoor installation with screen to protect the electrical interferences, in security and fire alarm system places where toxic gases should not exist.

Manufacturer:

BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

System of assessment and verification of constancy of performance of the product

System 3

The range of cables described in 1&2 belongs to Euroclass Eca **Euroclass Eca equals to System 3**

5. Notified Body: **NB 1783**

6. Declared Performance

Essential Characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Eca	EN 50575:2014/A1: 2016
Dangerous substances	None	

7. The performance of the product defined is suitable for the performance declared in Article 6.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 2.

Signed for and in name of the manufacturer by:

Product Development Manager:

İbrahim KILIÇ

Borsan Kablo Elektrik Aydınlatma Aş.

OSB Organize Sanayi Bulvarı No: 40-1

Tekkeköy / Samsun

T: +90 (362) 266 5925

F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Vali M. Erdoğan Cebeci Bulvarı No: 54

Tekkeköy / Samsun

T: +90 (362) 266 9914

F: +90 (362) 266 9989

E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr

01.11.2019