

# **DECLARATION of PERFORMANCE**

Number: BR-315

1. Unique identification code of the product:

N1XZ1 (Mono)

Diameter: From: 11.30 to 29.00

Number of conductors: 1

Conductor section (mm<sup>2</sup>): 25 - 300

2. Intended use of the product:

It is used in hospitals, schools, hotels, shopping centers, data processing centers, public transportation premises, tunnels and power plants.

Manufacturer:

BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

4. System of assessment and verification of constancy of performance of the product

# System 3

The range of cables described in 1&2 belongs to Euroclass Dca-s1, d2, a3 Euroclass Dca-s1, d2, a3 equals to System 3

NR 2184 5. Notified Body:

**Test Report Number: ERA-21-139** 

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Dca-s1, d2, a3	
Dangerous substances	None	EN 50575:2014/A1:2016

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

**Product Development Manager:** 

İbrahim KILIÇ 20.09.2021

### Borsan Kablo Elektrik Aydınlatma Aş.

OSB Organize Sanayi Bulvarı

No: 40-1 Tekkeköy / Samsun

T: +90 (362) 266 5925

F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr

E-posta: export@borsan.com.tr

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Vali M. Erdoğan Cebeci Bulyarı No: 54

Tekkeköy / Samsun

T: +90 (362) 266 9914

F: +90 (362) 266 9989

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr BORSAN KABLO ELEKTRIK



# **DECLARATION of PERFORMANCE**

Number: BR-314

1. Unique identification code of the product:

N1XZ1 (Multiple)

Diameter: From: 16.20 to 51.0 Number of conductors: 4 - 5

Conductor section (mm²): 10 - 240

2. Intended use of the product:

It is used in hospitals, schools, hotels, shopping centers, data processing centers, public transportation premises, tunnels and power plants.

Manufacturer:

BORSAN Kablo Elektrik Aydınlatma İnş. ve Tic. A.Ş Şabanoğlu OSB Mah. Organize Sanayi Bulv. No:40/1 Tekkeköy/Samsun / TURKEY

4. System of assessment and verification of constancy of performance of the product

# System 3

The range of cables described in 1&2 belongs to Euroclass Dca-s1, d2, a3 Euroclass Dca-s1, d2, a3 equals to System 3

NR 2184 5. Notified Body:

**Test Report Number: ERA-21-139** 

6. Declared Performance

Essential characteristics	Performance	Harmonized Technical Specification
Reaction to fire	Dca-s1, d2, a3	
Dangerous substances	None	EN 50575:2014/A1:2016

7. The performance of the product defined is suitable for the performance declared in Article 6.

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and in name of the manufacturer by:

**Product Development Manager:** 

İbrahim KILIÇ

### Borsan Kablo Elektrik Aydınlatma Aş.

Bakır Fabrika/Copper Factory | Alüminyum Fabrika/Aluminum Factory

OSB Organize Sanayi Bulvarı

No: 40-1 Tekkeköy / Samsun

T: +90 (362) 266 5925

F: +90 (362) 266 6194

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr

OSB Vali M. Erdoğan Cebeci Bulyarı No: 54

Tekkeköy / Samsun

T: +90 (362) 266 9914 F: +90 (362) 266 9989

E-mail: borsan@borsan.com.tr E-posta: export@borsan.com.tr

20.09.2021 BORSAN KABLO ELEKTRIK